



LEGEND	
	BALL VALVE
	CIRCULATING PUMP
	CHECK VALVE

NOTES:
 1. The temperature and pressure relief valve shall not exceed the pressure rating of the components in the system
 2. This is a standard pipe installation drawing. Consult local codes and authorities for additional necessities
 3. Verify all pipe diameters are sized correctly to handle the flow volume at maximum water velocity.

WARNING: Insulate or guard any hot water surfaces. Failure to insulate or guard steam and hot water surfaces can cause serious burns.

PROPRIETARY AND CONFIDENTIAL
 THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF THE ELECTRIC HEATER COMPANY. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF THE ELECTRIC HEATER COMPANY IS PROHIBITED.

REV.	DESCRIPTION	DATE	APPROVED
REVISIONS			
Hubbell The Electric Heater Company		Stratford, CT 06615 (203) 378-2659	
Customer:			
Description:			
MODEL E/SE/SH: SINGLE UNIT INSTALLATION DRAWING			
SIZE	DWG. NO.	REV.	
A			
SCALE: 1:1	FSCM: 19857	SHEET 1 OF 3	