



THE ELECTRIC HEATER COMPANY

45 SEYMOUR STREET / P.O. BOX 288

STRATFORD, CT 06615-0288

TEL: (203) 378-2659 FAX: (203) 378-3593

<http://www.hubbellheaters.com>

SERVICE BULLETIN

Bulletin No. 014

Issue Date: February 16, 2015

Product: Model J Booster Heaters

Component: Temperature and Pressure Relief Valve

Purpose: To provide field service technicians and other appropriate personnel with specific information regarding product service or operation.

Background: Currently all Hubbell J Model Booster Heater are supplied with relief valves sized to the CSA rating as follows.

1 to 27 kW, 100XL rated 105,000 BTU/hr per CSA and 200,000 BTU/hr per ASME

30 to 58.5 kW, 40XL rated 205,000 BTU/hr per CSA and 1,400,000 BTU/hr per ASME

Since the Hubbell J Model Booster Heaters are designed, manufactured, and stamped in accordance with ASME, the National Board of Boiler and Pressure Vessel Inspectors (the governing agency for ASME) states that the relief valves should be sized to the ASME rating. Therefore; as of the date of this Service Bulletin, Hubbell will be supplying 100XL relief valves with all its J Model Booster Heaters up to and including 58.5 kW (199,600 BTU/hr).

Action/Status: Effective February 16, 2015 All J6 and J16 booster heaters up to and including 58.5 kW will be supplied with the 100XL relief valve.