



THE ELECTRIC HEATER COMPANY

45 SEYMOUR STREET / P.O. BOX 288
STRATFORD, CT 06615-0288
TEL: (203) 378-2659 FAX: (203) 378-3593
<http://www.hubbellheaters.com>

SERVICE BULLETIN

Bulletin No. 008

Issue Date: July 9, 2007

Product: Model J Booster Heaters

Purpose: To provide field service technicians with specific information regarding product service or operation.

Background: Continuing our efforts to strengthen our position as the value-added leader in the marketplace, Hubbell will now provide dielectric unions with all J Model Booster Heaters. The dielectric unions will be supplied loose packaged in the accessory carton for installation in the field. The unions improve the quality and simplify the installation by providing the technician with unions so he does not "hard pipe" the booster. The unions supplied do more than provide an easy way to connect/disconnect the booster from the piping. Because they are dielectric unions they also isolate the booster from the plumbing system, which prevents corrosion due to stray currents either coming into or out of the booster.

Current Status: Effective as of July 11, 2007 all J Model Booster Heaters shipped from the factory will be supplied with the above referenced Dielectric Unions.

Remarks/Action: None